

| Item | Description | Qty | Unit | Rate | Amount |
|----------------------------|---|-----|------|------|--------|
| | <u>Fire Protection</u> Supply, deliver and install the following fire fighting equipment in positions indicated on the contract drawings or as shall be instructed by the Engineer. Supply and install the following fire fighting installation and equipment as described and shown on the drawings. Tenderers should allow for all fittings, jointings couplings including unions and clamps where necessary for the proper functioning of the installation when pricing. | | | | |
| | Hosereel Installation Hosereel 25mm diameter 30m long swinging type hose reel complete with delivery valve, mild steel feed pipe, isolation valve, guide and all other accessories as "Angus Fire Armour" or equal and approved. | | | | |
| A | | 12 | No. | | |
| | GMS pipe | | | | |
| B | 50mm diameter gms pipe class "B" | 80 | Lm | | |
| C | 25mm diameter gms pipe class "B" | 40 | Lm | | |
| | EXTRA OVERS | | | | |
| D | 50mm Bends | 15 | No. | | |
| E | 25mm Bends | 12 | No. | | |
| F | 50mm equal tee | 4 | No. | | |
| G | 50mm x 25mm Reducer | 3 | No. | | |
| H | 50mm gate valve sa peggler or approved equivalent | 6 | No. | | |
| I | 25mm -ditto- | 4 | No. | | |
| J | 50mm non-return valve | 2 | No. | | |
| | Reducers | | | | |
| K | 50 x 25 mm diameter reducer | 12 | No. | | |
| | Unions | | | | |
| L | 25mm diameter pipe unions | 7 | No. | | |
| M | 50mm diameter pipe unions | 14 | No. | | |
| Total carried to next page | | | | | |